



# ISO New England's Strategic Transmission Analysis

---

*New England Electricity Restructuring Roundtable:  
Generation Retirement Study & 2020 Resource Options*

**Stephen Rourke**

VICE PRESIDENT, SYSTEM PLANNING



# Five Regional Challenges Identified




1. Resource performance and flexibility
2. Increased reliance on natural-gas-fired capacity
3. ***Retirement of generators***
4. Integration of a greater level of variable resources
5. ***Alignment of markets and planning needs improvement***

**Strategic  
Transmission  
Analysis (STA)  
to shed light on  
two challenges**



# Strategic Transmission Analysis Study Objective

- Evaluate the reliability impacts associated with the retirement of 28, 40+ year-old coal- and oil-fired resources by 2020
- Determine whether these retirements totaling 8.3 GW pose transmission security or resource adequacy issues




# Capacity Resources Assumed to be at Risk of Retirement (from 2010 Economic Study)

Unit	Unit Type	MW Maximum Assumed	In-service Date	Age in 2020	Unit	Unit Type	MW Maximum Assumed	In-service Date	Age in 2020
BRAYTON POINT 1	Coal	261	01-Aug-63	57	MONTVILLE 6	Oil	418	01-Jul-71	49
BRAYTON POINT 2	Coal	258	01-Jul-64	56	MOUNT TOM 1	Coal	159	01-Jun-60	60
BRAYTON POINT 3	Coal	643	01-Jul-69	51	MYSTIC 7 GT	Oil	615	01-Jun-75	45
BRAYTON POINT 4	Oil	458	01-Dec-74	46	NEW HAVEN HBR	Oil	483	01-Aug-75	45
BRIDGEPORT HBR 2	Oil	190	01-Aug-61	59	NEWINGTON 1	Oil	424	01-Jun-74	46
BRIDGEPORT HBR 3	Coal	401	01-Aug-68	52	NORWALK HBR 1	Oil	173	01-Jan-60	60
CANAL 1	Oil	597	01-Jul-68	52	NORWALK HBR 2	Oil	179	01-Jan-63	57
CANAL 2	Oil	599	01-Feb-76	44	SCHILLER 4	Coal	51	01-Apr-52	68
MERRIMACK 1	Coal	121	01-Dec-60	60	SCHILLER 6	Coal	51	01-Jul-57	63
MERRIMACK 2	Coal	343	30-Apr-68	52	W. SPRINGFIELD 3	Oil	111	01-Jan-57	63
MIDDLETOWN 2	Oil	123	01-Jan-58	62	YARMOUTH 1	Oil	56	01-Jan-57	63
MIDDLETOWN 3	Oil	248	01-Jan-64	56	YARMOUTH 2	Oil	56	01-Jan-58	62
MIDDLETOWN 4	Oil	415	01-Jun-73	47	YARMOUTH 3	Oil	122	01-Jul-65	55
MONTVILLE 5	Oil	85	01-Jan-54	66	YARMOUTH 4	Oil	632	01-Dec-78	42

**TOTAL 8,281 MW**

# Future Transmission Incorporated into Study



- Regional transmission projects expected to be in service before 2020 were included in study
- These transmission projects facilitate retirements, improve deliverability of existing resources, and provide significant flexibility for locating new replacement resources

# Transmission Projects Impact Retirements

- **NEEWS**
  - Allows higher import capability into CT and RI; improves east-west and west-east transferability; and, at least in part, facilitates retirements in Boston, eastern and western MA, RI and CT
- **Greater Boston**
  - Upgrades improve import capability into Boston; has a positive impact on facilitating retirements and delivery of NH and ME resources to Boston
- **Long-Term Lower SEMA**
  - Facilitates improved load serving capability in lower SEMA/Cape Cod area allowing for the retirement of some resources in SEMA
- **Maine Power Reliability Program**
  - Facilitates deliverability to load in Maine and supports possible retirements of at-risk resources
- **Vermont/New Hampshire**
  - Affect deliverability in VT/NH areas facilitating reliable retirements of at-risk resources in NH

# Retirements Alone Result in Capacity Shortfalls

*Region will be challenged to meet 2020 Installed Capacity Requirements absent replacements, repowering or the addition of new resources*


Qualified Capacity Assumed Available in 2020 including EE Forecast	37,000 MW
Representative Installed Capacity Requirement in 2020 (net of HQICC)	34,600 MW
Margin Before Potential Retirement of At-Risk Units	2,400 MW
Amount of At-Risk Generation	8,300 MW
<b>Shortfall After Retirements</b>	<b>- 5,900 MW</b>

**Retirement of At-Risk Units without replacements or new resources will result in shortfall of ICR**

<b>Shortfall After Retirements</b>	<b>- 5,900 MW</b>
April 2013 Generator Interconnection Queue*	5,200 MW
<b>Shortfall plus queue</b>	<b>-700 MW</b>

**Adding existing queue still results in shortfall**

\* Generator Interconnection Queue includes nameplate capacity – note almost 40% of April 2013 queue is wind generation



# Three Retirement Scenarios Evaluated

## Scenario I

Existing generation with no new replacement resources

## Scenario II

At-risk resources are replaced at the hub, and critical resources are retained at existing sites

## Scenario III


At-risk resources are replaced at the hub, and critical resources are repowered at existing sites

Each retirement analysis evaluates how much generation can be retired, recognizing:

- Resource needs
- Existing capacity constraints
- Area transmission security

# Application of New England Trading “Hub”


- New England Trading Hub (Hub) is a central trading location in energy market where no significant energy congestion is expected
  - 32 electrical buses/nodes in West-Central Massachusetts make up the Hub
  - Interconnection of new proxy generation at the Hub was represented by six 345 kV buses/nodes\*
- Replacement resources needed were envisioned to be integrated at the Hub



\* W. Medway 345 kV is electrically close to, but not in the defined Trading Hub

# Scenario I

*With assumed resources and transmission in 2020, no more than 950 MW may be retired without causing reliability problems*




- Issues caused by retirements:
  - Resource deficiency
  - Area and local transmission constraints
- Observations:
  - Maximum amount of retirement capacity that can be achieved is 950 MW
  - More resources can retire if replaced by new resources to meet capacity needs
  - Approximately 1,400 MW of existing capacity will be limited in effectiveness due to deliverability constraints

# Scenario II

*Assumes all units retired, except at critical resource sites; remaining resource needs met by new resources at the Hub*


- Issues caused by retirements:
  - Area and local transmission constraints
- Observations
  - SEMA import transmission constraints would require continued operation of assumed at-risk resources in SEMA
  - Local transmission constraints would require continued operation of assumed at-risk resources in Connecticut
  - Some existing resources will need to be retained, repowered or replaced; otherwise transmission upgrades will be necessary
  - Up to 5,100 MW of replacement resources at the Hub needed
  - Integrating resources to the Hub appears to be more deliverable than some existing resource sites



# Scenario III

*Assumes all units retired; repowering of critical resource sites; remaining resource needs met by new resources at the Hub*

- Issues caused by retirements:
  - Area import and local transmission constraints
- Observations:
  - 900 MW are needed to address SEMA import constraints and CT local constraints
  - SEMA import constraint can be addressed by adding generation at multiple sites
  - Local constraints within CT must be addressed electrically close to existing generation sites
  - Approximately 5,100 MW of replacement capacity at the Hub is required to replace lost capacity due to retirement of all the other at-risk resources



# Overall Observations


- If 8,300 MW retire by 2020, resource adequacy needs dictate replacement capacity of at least 5,900 MW plus almost 800 MW of new energy efficiency reflected in EE forecast
- With the currently planned system configuration at least 900 MW of the 5,900 MW replacement capacity must be in specific locations due to transmission constraints
  - 500 MW must be in SEMA
  - 400 MW must be in Connecticut
- Approximately 5,000 MW may need to be integrated into Hub
  - Transmission may be needed to make resources deliverable to the Hub
  - From Hub power can be delivered to the load

## Overall Observations, *continued*

- If substitute resources are not available, only 950 MW of the existing 8,300 MW of older oil and coal resources will be able to retire without causing reliability problems
- Major transmission projects significantly improve deliverability of most existing resources, and greatly facilitate retirement of assumed at risk resources
- Repowering all existing sites would likely result in congested capacity, thereby increasing the amount of capacity that needs to be replaced, compared to a scenario where the replacement capacity is deliverable to the Hub

## Overall Observations, *continued*

- New zonal definitions may need to be considered
  - Zones may not resemble current definitions (*i.e.*, state boundaries)
- Actual retirement requests will be evaluated as submitted based on prevailing system conditions
- This study focused on the year 2020, assuming all major transmission projects were already in service
  - Individual retirements may trigger local transmission reliability issues that were not captured in this study



# Questions

